

FORM FOR PROPOSALS ON NFPA TECHNICAL COMMITTEE DOCUMENTS

Mail to: Secretary, Standards Council
National Fire Protection Association, 1 Batterymarch Park, Quincy, Massachusetts 02269-9101
Fax No. 617-770-3500

If you need further information on the standards-making process, please contact the

Standards Administration Department at 617-984-7249.
For technical assistance, please call NFPA at 617-770-3000

Note: All proposals must be received by 5:00 p.m. EST/EDST on the published proposal-closing date.
Please indicate in which format you wish to receive your ROP/ROC: [] electronic or [X] paper

Date 6/30/99 Name James C. Belke Tel. No. (202) 260-7314

Company United States Environmental Protection Agency

Street Address 401 M. Street, SW, Washington, DC 20460 / Mail Code 5104

Please Indicate Organization Represented (if any) United States Environmental Protection Agency

1. a) NFPA Document Title Liquefied Petroleum Gas Code NFPA No. & Year NFPA-58, 1998 Edition

b) Section/Paragraph Section 9-4 (new subsection)

2. Proposal Recommends: (Check one) [X] new text
[] revised text
[] deleted text

FOR OFFICE USE ONLY
Log #
Date Rec'd

3. Proposal (include proposed new or revised wording, or identification of wording to be deleted): (Note: Proposed text should be in legislative format: i.e., use underscore to denote wording to be inserted (inserted wording) and strike-through to denote wording to be deleted (deleted wording).)

New subsection:

9-4.4 Refrigerated LP-Gas containers and systems at bulk plants, industrial occupancies, and industrial plants shall comply with 3.3-3 through 3.3-7.

Note to committee: sections 3.3-3 through 3.3-7 cited above refer to proposed new sections for operations, maintenance, fire safety analysis, audits, and inspections at bulk plants, industrial occupancies, and industrial plants (see separate EPA proposal for substantiation and additional details).

4. Statement of Problem and Substantiation for Proposal: (Note: State the problem that will be resolved by your recommendation; give the specific reason for your proposal including copies of tests, research papers, fire experience, etc. If more than 200 words, it may be abstracted for publication.)

This proposal extends proposed new requirements for maintenance, operations, fire safety analysis, audits, and inspections to refrigerated LP-Gas containers (see separate proposal for substantiation and additional details). The proposed additions apply only to refrigerated LP-Gas containers and systems at bulk plants, industrial occupancies, and industrial plants.

5. [] This Proposal is original material. (Note: Original material is considered to be the submitter's own idea based on or as a result of his/her own experience, thought, or research and, to the best of his/her knowledge, is not copied from another source.)

[X] This proposal is not original material; its source (if known) is as follows: Sources include API Recommended Practices, CCPS Plant Guidelines for Technical Management of Chemical Process Safety, 40 CFR Part 68 (the EPA Risk Management Program), and 29 CFR Part 1910.119 (the OSHA Process Safety Management Standard).

Note 1: Type or print legibly in black ink.

Note 2: If supplementary material (photographs, diagrams, reports, etc.) is included, you may be required to submit sufficient copies for all members and alternates of the technical committee.

I hereby grant the NFPA all and full rights in copyright, in this proposal, and I understand that I acquire no rights in any publication of NFPA in which this proposal in this or another similar or analogous form is used.

Signature (Required)

PLEASE USE SEPARATE FORM FOR EACH PROPOSAL